



ADDENDUM NO. 2

PROJECT NAME: Tom Slick Park

DATE: 03/13/2025

PROJECT NO: 23-04027

This addendum is separated into sections for convenience; however, all respondents, bidders, contractors, subcontractors, material men, and other parties must be responsible for reading the entire addendum. The failure to list an item or items in all affected sections of this addendum does not relieve any party affected from performing as per instructions, providing that the information is set forth one time any place in this addendum. These documents will be attached to and will become part of the Contract Documents for this project. The respondent/bidder is required to acknowledge the receipt of this addendum.

GENERAL:

1. The following changes and/or additions to the Contract Documents, via this addendum, must apply to proposals made for and to the execution of the various parts of the work affected thereby.
2. Careful note of the Addendum must be taken by all interested parties and all trades affected must be fully advised in their performance of the work involved.
3. This Addendum is hereby made part of the project requirements and contract documents for the above reference project. Ensure to acknowledge this Addendum in CivCast when downloading this Addendum. Acknowledgement of this Addendum is a requirement in order to submit bid in CivCast. This addendum consists of the items and their associated attachments as listed below:

A. QUESTIONS & RESPONSES:

1. **Q:** Hello, looking at the Detail: Pole Base in sheet L1.02, it asks for "LIGHT POLE & FIXTURE SHALL BE: AS SPEC., SEE SECTION 01900- DESIGN SELECTIONS". I believe there is no SECTION 01900 within the Specifications. Can you please provide SECTION 01900 to see the design selections? Thank You.
A: The design selection for the solar lights is in Specification Section 12 93 00- Site and Street Furnishings. However, the light fixture specified has been discontinued. Please price Aeromax Solar Light instead. Contact information for Green Frog Systems is as specified: www.greenfrogsystem.com (214) 838-7010.
2. **Q:** Will substitutions be accepted on the solar lights?
A: Substitutions may be accepted; however, all information must be provided showing how the substituted fixture meets all the specifications. See Section 12 93 00- Site and Street Furnishings for initial requirements.

3. **Q:** Is the 40-hour training that is required and mandatory for the company project managers, supervisors, foreman and/or employees? Who would be considered a Trainee?
A: The 8-hour Supervisory training and 40 hours of Hazwoper training is required for the project. The designated supervisor must remain on-site and have the 8-hours of Supervisory training, and any worker handling soils below the two-foot landfill cap is required to have the 40-hour hazwoper training.

SIGNED AND SEALED BY CONSULTANT (Engineer/Architect of Record)

By signing and sealing this addendum, the Engineer/Architect of Record acknowledges that the sign/seal is only for changes/clarifications to the items associated with the Engineer's/Architect's work referenced in this addendum.



David Rios

David Rios
Procurement Manager
Finance Department - Procurement Division

END OF ADDENDUM NO. 2