ADDENDUM 5

SUBJECT: Texas A&M University Area Streets (Maria Ferrier Ave. to Mauermann Road) Phase 2 (2022 Bond), (WBS: 23-03921A), Scheduled to Close: November 6, 2026; Date of Issue: October 2, 2026

FROM: Jaime E. Contreras
Procurement Manager

DATE: November 6, 2026

THIS NOTICE SHALL SERVE AS ADDENDUM NO. 5 – TO THE ABOVE REFERENCED INVITATION FOR BID

This addendum is divided into sections for convenience only. All Respondents are responsible for reviewing the entire addendum. Compliance is required for any item included in this addendum, even if it appears only once. All interested parties and affected trades must review this addendum carefully and ensure full compliance in performing the related work. All documents in this addendum shall be attached to and incorporated into the Contract Documents.

Respondents and bidders shall be responsible for reading the entire addendum. All addenda issued for this solicitation shall be attached to and become part of the solicitation and resulting contract documents for this project. By submitting a response to a City solicitation, respondent/bidder is acknowledging the receipt of this addendum.

By virtue of this addendum, the specifications, requirements and amendments stated below become a permanent addition to the solicitation referenced above and any other supporting solicitation documents and postings.

THE ABOVE MENTIONED INVITATION FOR BID IS HEREBY AMENDED AS FOLLOWS:

CHANGES TO SOLICITATION

1. **Bid Opening:**
   a. Current: November 6, 2026
   b. Revised: November 10, 2026

QUESTIONS SUBMITTED VIA EMAIL AFTER THE QUESTION CUTOFF DATE

Question 1: Is CPS providing the materials?

Response: CPS will provide the streetlight bases for the contractor to install. The contractor is responsible for providing and installing the 2.5” grey, schedule 40 conduit.

Question 2: For the bid item 2.5 conduit is it only the install of the conduit? There is a CPS Cable Schedule that shows wiring but no pay item. Is the wiring and the pulling of the wiring subsidiary to the conduit item? Looking in all of the bid documents it is not clear.

Response: The contractor is responsible for providing and installing the 2.5" grey, schedule 40 conduit. CPS Energy will provide the wiring, install the wiring and connect the wiring to the streetlights after the conduit and streetlight bases have been installed.

REVISIONS TO CONSULTANT'S DOCUMENTS (SPECIFICATIONS, PLANS, BID FORM, ETC.)

Consultant's revisions will be issued as an attachment to this addendum.

1. Bid Form
   a. N/A

2. Plans
   a. N/A

3. Specifications
   a. N/A

SIGNED AND SEALED BY CONSULTANT (Engineer/Architect of Record). By signing and sealing this addendum, the Engineer/Architect of Record acknowledges that the sign/seal is only for changes/clarifications to the items associated with the Engineer's/Architect's work referenced in this addendum.



TBPE FIRM #0455

Jaime E. Contreras

Jaime E. Contreras
Procurement Manager
Finance Department, Procurement Division