Docusign Envelope ID: E128AF85-21B9-88EF-8177-9FAACC5BCFD6

ADDENDUM I

SUBJECT: Poured in Place (PIP) Rubber Playground Safety Surfacing Application, (IFB 6100019963), Scheduled to Close: Wednesday, November 18, 2026; Date of Issue: Friday, October 30, 2026

FROM: Jorge D. Figueroa
Procurement Manager

DATE: November 16, 2026

THIS NOTICE SHALL SERVE AS ADDENDUM NO. I - TO THE ABOVE REFERENCED INVITATION FOR BID

Respondents and bidders shall be responsible for reading the entire addendum. All addenda issued for this solicitation shall be attached to and become part of the solicitation and resulting contract documents for this project. By submitting a response to a City solicitation, respondent/bidder is acknowledging the receipt of this addendum.

By virtue of this addendum, the specifications, requirements and amendments stated below become a permanent addition to the solicitation referenced above.

THE ABOVE-MENTIONED INVITATION FOR BID IS HEREBY AMENDED AS FOLLOWS:

1. The bid opening date is hereby extended to Monday November 23, 2026, at 2:00 P.M. Central Time.

QUESTIONS SUBMITTED IN ACCORDANCE WITH SECTION 003, RESTRICTIONS OF COMMUNICATION:

Question 1: In the five-year contract, if there are discrepancies in price escalation, are we able to price it accordingly throughout the five-year period?

Response: Section 005 – Supplemental terms and conditions, Date for Adjustment states; Prices may be adjusted annually (the" Price Adjustment Date") Vendor must hold prices firm for first 12 months of the original contract term to request a price adjustment.

Question 2: Has the City of San Antonio specified Critical Fall Height that the PIP surfacing for the annual contract should be priced at? There is a slight variation in pricing for different fall heights and we want to make sure we provide the City of the most accurate pricing possible. We are not sure if we should price this at a standard 6" CFH and note that there will be a potential for pricing differences. Or if the City would like to see multiple pricing sheets for different fall heights.

Response: For pricing purposes, the CFH should be 6". However, the actual CFH for the pour in place rubber will be determined in the field and the pricing for the specific site will need to be done for that site.

Question 3: What are the fall height requirements for the safety surfacing, per park?
Response: The fall height requirements are determined per playground, per site. Based upon ASTM standards, the fall height requirements will be based upon the playground CFH.

Question 4: What is the estimated Annual Quantity of Roll coat Maintenance?
Response: Estimate quantity of Roll Coat maintenance is 1,000 SF

Question 5: Would the City prefer Aromatic or Aliphatic binder?
Response: The City preference is Aromatic binder.

Question 6: Does demo need to be included in price?
Response: Yes, demo needs to be included in the price.

Question 7: The RFP calls for a bid bond, but there is no specific overall dollar amount. Do you know the total value of contract?
Response: This bid solicitation is a Formal Invitation for Bid ("IFB") as listed on the cover page. This Section 005 – Supplemental terms and conditions, Bid Bond states; Bidder must submit a bid/proposal bond, in a form acceptable to City, made payable to the City of San Antonio, executed by a corporate surety acceptable to City who is licensed pursuant to the Texas Insurance Code and listed on the United States Department of the Treasury's Listing of Approved Sureties (Dept. Circular 570) in the amount of no less than 5% of the total amount of the bid

_____ Original Signature of Person Authorized to Sign Bid/Contract (Please Sign) _____ Signer's Name (Please Print) _____ Vendor Name _____ Vendor Address _____ City _____ State, Zip code	Jorge Figueroa _____ Jorge D. Figueroa, Procurement Manager Finance Department, Procurement Division