



## **ADDENDUM II**

**SUBJECT:** Fire Station # 53 Replacement (RFCSP 2024-169) Scheduled to Close: Friday, November 22, 2024; Date of Issue: Friday, September 20, 2024

**FROM:** Jonathan Miranda, MSJP  
Procurement Administrator

**DATE:** November 13, 2024

### **THIS NOTICE SHALL SERVE AS ADDENDUM NO. II – TO THE ABOVE REFERENCED REQUEST FOR COMPETITIVE SEALED PROPOSALS**

This addendum is separated into sections for convenience; however, all Respondents, and other parties shall be responsible for reading the entire addendum. The failure to list an item or items in all affected sections of this addendum does not relieve any party affected from performing as per instructions, providing that the information is set forth one time any place in this addendum. These documents shall be attached to and become part of the Contract Documents for this project. The Respondent shall be required to acknowledge the receipt of this addendum.

- 
1. The following changes and/or additions to the Contract Documents, via this addendum, shall apply to submittals made for and to the execution of the various parts of the work affected thereby.
  2. Careful note of the addendum shall be taken by all interested parties and all trades affected shall be fully advised in their performance of the work involved.

### **THE ABOVE-MENTIONED REQUEST FOR COMPETITIVE SEALED PROPOSALS IS HEREBY AMENDED AS FOLLOWS:**

#### **GENERAL INFORMATION**

1. **Add:** Revisions to Plans and Specifications – Addendum 5 Alamo Architects.

#### **REVISIONS TO CONSULTANT’S DOCUMENTS (SPECIFICATIONS, PLANS, ETC.)**

1. Consultant’s revisions will be posted as a separate file.

Items include:

- a. Revisions to Plans and Specifications – Addendum 5 Alamo Architects.

**QUESTIONS SUBMITTED IN ACCORDANCE WITH SECTION VIII.3,**  
**RESTRICTION OF COMMUNICATIONS:**

**QUESTIONS SUBMITTED**

- Question 1: E100: There are numerous “new light poles” shown on this sheet but no circuitry or fixture type?  
Response: New light poles were designated circuits and fixture type in Addendum #1 Alamo Architects.
- Question 2: E100: There are 2 Docking Stations shown on this sheet but only one on the riser?  
Response: A distinction was made in Addendum #1 between the Docking Station and Generator Termination Box.
- Question 3: E100: No locations for the Command Bus or 600A Generator termination box shown on this sheet or on the floor plans?  
Response: Command Bus and Generator Termination Box are shown on site plan in Addendum #1.
- Question 4: E100: No fixture type or circuit shown for KN#4  
Response: Fixture type and circuit for KN#4 designated in Addendum #1.
- Question 5: E100: No circuit numbers found for pole mounted receptacles.  
Response: Pole mounted receptacles were designated circuits in Addendum #1.
- Question 6: E200: Verify corridor switching.  
Response: Refer to lighting controls general notes for corridor switching requirements
- Question 7: E200: What are 2-\$OS shown outside near G2? Clarify.  
Response: Exterior \$O2 were removed in Addendum #2.
- Question 8: E200: Dayroom has apparently 3 zones of switches, but 5 zones controlled (a-e). Clarify.  
Response: Fixtures with control designations d and e are part of the kitchen lighting and shall be provided with separate control zones
- Question 9: E300: In the dorm rooms there is a duplex receptacle symbol shown but with an additional line through the legs of the receptacle. This symbol is not on the symbol schedule. Clarify.  
Response: This is a visual error with the Revit Family. All circuit shown with that visual are the above counter (AC) USB receptacles for the desk areas.
- Question 10: E300: The “Command Truck Receptacle” is not shown on the riser and there is no detail 2 on E601. Is this the 200A Command Bus?  
Response: Note referring to Detail 2 was removed in Addendum #1. It is a 200A Command Bus. Refer to One-Line Diagram and KN#7 on sheet E600.
- Question 11: E600: Per sheet E100 the CPSE transformers will be pole mounted with empty conduit to the CT cabinet, not as detailed on this riser.  
Response: CPSE Transformer shown on the one-line diagram is for the new 120/208V, 3PH electrical service. Sheet E100 shows both the existing and new CPSE transformers. The existing conduit from the existing transformer to the CT cabinet will be abandoned in place and capped after new electrical service is installed, per the note on E100. Refer to Addendum #1.

Question 12: E600: The “Command Bus” and “Generator Termination Box” are not located on the site or floor plans. Clarify.

Response: Command Bus and Generator Termination Box are both shown on site plan E100 in Addendum #1.

Question 13: E600: Is the “Command Bus” just a no-fuse disconnect or some special box?

Response: As shown on the one-line diagram, the Command Bus will consist of a Disconnect and command bus connections. Refer to KN#7 on one-line diagram sheet E600.

Question 14: E600: There will need to be a 400/2F400 disconnect mounted adjacent to transformer T-1 and then the disconnect at the existing service will be a no-fuse disconnect. This is necessary to provide protection of the secondary feeders.

Response: Transformer ‘T-1’ was removed in Addendum #1.

Question 15: E700: Many of the listed wire & conduit are incorrect. (CB-1, CU-4, all FCU’s, KEF-1)

Response: CB-1 and KEF-1 were removed from equipment connection schedule in Addendum #1. Wire & Conduit for CU-4 and FCU’s were sized using designated ampacity and MOCP per NEC T310.15(B)(16), 75C Rating. Refer to addendum No. 1 drawings.

Question 16: E700: The disconnects on the 120/1 circuits will be motor rated switches which have not been listed as such.

Response: Refer to contract documents (drawings and specifications) for equipment product requirements.

Question 17: E700: All EF’s have factory installed disconnects.

Response: Refer to contract documents (drawings and specifications) for equipment product requirements.

Question 18: E800: Circuit breakers for SPD’s not shown in panel schedules.

Response: SPD was added to panel MDP in Addendum #1. Remaining panels were assigned spare breakers for SPDs, though not designated on the schedules.

Question 19: E800: Many panels not shown with AIC rating, we will assume 10,000 AIC.

Response: AIC ratings are shown in Addendum #1.

Question 20: E300/KN#6: Why is a 30/2F disconnect specified as the circuit is 20/1 and a motor rated toggle switch will suffice.

Response: Refer to contract documents (drawings and specifications) for equipment product requirements.

Question 21: E700: Why are disconnect shown for the 7 CU units when panel AC has been placed to eliminate their need as shown in detail 2/E500?

Response: Refer to contract documents (drawings and specifications) for equipment product requirements

Question 22: E700: Why is circuit for ERV #8?

Response: Circuit for ERV-1 is connected to panel P4 circuit #18. Feeder size is as shown in schedule: (2) #10 PHASE, (1) #10 GROUND, IN ¾” CONDUIT.

Question 23: E700: Per panel schedules circuitry for gates, controllers & septic tank are existing to remain.

Response: Correct. Gates, controllers, and Septic system are shown to reflect complete list of devices, existing included.

- Question 24: M600: There is no such 60A MOCP size as listed for MSCU-IDF. The breaker serving this unit will may have to be changed.  
Response: Refer to equipment connection schedule.
- Question 25: E700: It appears the fixtures type EX-5E & GE are to include battery backup which has not been scheduled.  
Response: Fixture type 'GE' is scheduled to be connected to backup power generator on life safety panel 'LS1' per Addendum #1. Type 'EX-5E' is connected to optional stand-by panel 'P1B1' per Addendum #1.
- Question 26: E100: Lighting Control General Notes – No lighting control system on this job as all zones are listed as local control only. No UL924 devices as all 'E' fixtures are onboard batteries only.  
Response: All lighting systems are connected to Generator through either Life Safety Panel 'LS1' or optional stand-by panel 'P1B1' per Addendum #1.
- Question 27: KN#13/E300: Is the conduit to the antennae to be ¾"? 3" not industry standard.  
Response: Refer to keyed note No. 12. Drawings call for a 3" Conduit.
- Question 28: KN#17/E300: It appears, but is not abundantly clear, that all door lift motors in the existing building are existing, and no further provisions required.  
Response: KN#17 is for all devices that will be existing to remain, including the door lift motors. As note states, "Device information obtain from as-built documents".
- Question 29: KN#8/E300: Correct reference to 1/E900.  
Response: KN#8 should reference to 2/E900 for pedestrian warning lights detail.
- Question 30: 1/E900: It is understood since there is a pullcord and no actual control conductors for these warning signs that these signs will be provided by others at a future date.  
Response: Contractor to provide and install traffic warning sign device, including all control wiring and associated devices for a complete functioning installation.
- Question 31: KN#8/E300 - KN#1/E100 states the control conduit is to be routed to the Joker Stand. Why is this outlet located elsewhere? Per M100 there is a gas detection system at this location, is this note not properly located?  
Response: Pedestrian warning lights control conduit should be located in the Joker Stand.
- Question 32: KN#9/E300: No control wire/conduit has been specified. Are these wireless controller locations? Verify 5 and not 6 boxes.  
Response: Reference boxes are for fire bay overhead door wired controllers.
- Question 33: KN#10/E300: Per E100 and panel schedules these gates are existing to remain. Where is the existing control to be intercepted and extended?  
Response: Gate Keypad is shown existing to remain on site plan. Gate operator circuits are existing to remain.
- Question 34: KN#12/E300: What are controls required for air scrubber? Please provide a detail of these requirements if we are to include with this bid.  
Response: Existing Air Scrubbers are to be removed. KN#12 is for the Antenna JBox. The fire stations will include new Plymovent exhaust systems. Refer to Equipment tag VEF-1 and VEF2.

Question 35: KN#14/E300: This note is shown in Dorm room 124 & typical in Officer door room. No motorized door found in these rooms. Clarify.

Response: KN#14 is Typical for all Dorms and Officer Dorms. KN#14 is for TV receptacles. KN#13 is for motorized doors.

Question 36: KN#15/E300: Note not found on floor plans.

Response: Note shown on floor plan in EMS Bay, along grid line H.1.

Question 37: KN#16/E300: This note does not appear to be applicable to this location. Clarify.

Response: KN#16 is shown because the Jbox is for the Baby Box connection. Note is for clarification on location of Baby Box.

Question 38: On page M100 there shows a total of (15) Temp sensors being connected to the diffusers in the dorm rooms. What is your intent? There is no specification for these that we can find for a smart diffuser with a motorized damper.

Response: Refer to Addendum #01 for the removal of the BAS system from the project.

Question 39: Specifications Page 230900A-8 1.16 Training: Is that a typo? Is the owner asking for 80hrs? We usually provide 8 hrs.

Response: Refer to Addendum #01 for the removal of the BAS system from the project.

Question 40: Is there an existing BAS system in the building?

Response: Refer to Addendum #01 for the removal of the BAS system from the project.

Question 41: Could you let me know what the COSA bonding requirements are for this project? Is going to be a 5% bid bond, and a 100% P&P bond?

Response: The Bid Bond is 5% of the total bid and the Performance and Payment Bonds are 100%.

**End of Addendum #2.**

DocuSigned by:

*Jonathan Miranda*

6DB82DC69B2F4CB...

---

Jonathan Miranda, MSJP  
Procurement Administrator  
Finance Department - Procurement Division



## Addendum 5

11/7/2024



**Project: CoSA Fire Station 53**  
**Alamo Architects Job Number: 2023-04**

## Addendum 5

11/07/2024

---

This addendum shall be included in and be considered part of the plans and specifications for the above-named project. The Contractor shall be required to sign and acknowledge receipt of this addendum at the time she/he receives it.

This addendum contains changes to the requirements of the Contract Drawings and Specifications. Such changes shall be incorporated in the Contract Documents and shall apply to the work with the same meaning and force as if they had been included in the original Documents. Whenever this Addendum modifies a portion of a paragraph of the Specifications, or any portion of any Drawing, the remainder of the paragraph or drawings affected shall remain in force.

The conditions and terms of the basic specifications shall govern work described in this Addendum. Whenever performance and the quality or quantity of materials, or workmanship are not fully described in this Addendum, the PERFORMANCE REQUIREMENTS of the Specifications shall apply to the work described in this Addendum.

If no similar items of work are included in the basic specifications, the best quality of material and workmanship standards shall apply and all work shall be subject to the written approval of the Architect.

---

## Narrative

### Architecture

Item No. A1: Addition of project sign template(s) provided by the City of San Antonio to the Appendix of the project manual.

### LIST OF ATTACHMENTS:

**Specs Revised: 000110 (TOC), Appendix B (Construction site "project" display)**

**COSA FIRE STATION NO. 53****Alamo Architects**  
**Project No. 2023-04****ADDENDUM #5**

## SECTION 000110 – TABLE OF CONTENTS

Following listed documents and sections comprise the Project Manual for the Work. Where numerical sequence of documents and sections is interrupted, such interruptions are intentional.

Project Manual for the Work shall not be separated for any reason. Owner and Architect disclaim responsibility for any interpretation, assumption or action made because of not receiving a complete Project Manual.

DOCUMENT/SECTION

000000	COVER PAGE
000110	TABLE OF CONTENTS

## DIVISION 1 – GENERAL REQUIREMENTS

**\*\*REFER TO THE CITY OF SAN ANTONIO'S 'GENERAL CONDITIONS FOR CITY OF SAN ANTONIO CONSTRUCTION CONTRACTS' FOR ADDITIONAL REQUIREMENTS\*\***

011000	SUMMARY OF WORK
012000	PRICE AND PAYMENT PROCEDURES
012300	ALTERNATES
013000	ADMINISTRATIVE REQUIREMENTS
014000	QUALITY REQUIREMENTS
014339	MOCKUPS
015000	TEMPORARY FACILITIES AND CONTROLS
016000	PRODUCT REQUIREMENTS
017000	EXECUTION AND CLOSEOUT REQUIREMENTS
017800	CONTRACT CLOSEOUT

## DIVISION 2 – SITE CONSTRUCTION

024113.13	REMOVAL OF EXISTING CONCRETE
024119	SELECTIVE DEMOLITION

## DIVISION 3 – CONCRETE

033000	CAST-IN PLACE CONCRETE
033536	POLISHED CONCRETE FLOOR FINISHING

## DIVISION 4 – MASONRY

042000	UNIT MASONRY
044313.13	ANCHORED STONE MASONRY VENEER (ALTERNATE #01)
047200	CAST STONE MASONRY

## DIVISION 5 – METALS

050519	POST INSTALLED ANCHORS
051200	STRUCTURAL STEEL
051213	ARCHITECTURALLY EXPOSED STRUCTURAL STEEL FRAMING

**COSA FIRE STATION NO. 53**

**Alamo Architects  
Project No. 2023-04**

**ADDENDUM #5**

052100	STEEL JOISTS
053100	STEEL DECK
054000	COLD-FORMED METAL FRAMING
055000	METAL FABRICATIONS

**DIVISION 6 – WOOD AND PLASTICS**

061000	ROUGH CARPENTRY
061600	SHEATHING
064023	INTERIOR ARCHITECTURAL WOODWORK

**DIVISION 7 – THERMAL AND MOISTURE PROTECTION**

072100	THERMAL INSULATION
072726	FLUID-APPLIED MEMBRANE AIR BARRIERS
074113.16	STANDING-SEAM METAL ROOF PANELS
074213	FORMED METAL WALL PANELS
074293	METAL SOFFIT PANELS
076200	SHEET METAL FLASHING AND TRIM
078400	THROUGH PENETRATION FIRESTOP SYSTEMS
078443	JOINT FIRESTOPPING
079200	JOINT SEALANTS

**DIVISION 8 – DOORS AND WINDOWS**

081113	HOLLOW METAL DOORS AND FRAMES
081416	FLUSH WOOD DOORS
083113	ACCESS DOORS AND FRAMES
083600	SECTIONAL OVERHEAD DOORS
084113	ALUMINUM-FRAMED ENTRANCES AND STOREFRONTS
087100	DOOR HARDWARE
088000	GLAZING
089119	FIXED LOUVERS

**DIVISION 9 – FINISHES**

092216	NON-STRUCTURAL METAL FRAMING
092900	GYPSUM BOARD
093000	TILING
095113	ACOUSTICAL PANEL CEILINGS
096513	RESILIENT BASE AND ACCESSORIES
096519	RESILIENT TILE FLOORING
096566	RESILIENT ATHLETIC FLOORING
099113	EXTERIOR PAINTING
099123	INTERIOR PAINTING
099600	HIGH-PERFORMANCE COATINGS

**COSA FIRE STATION NO. 53**

**Alamo Architects**  
**Project No. 2023-04**

**ADDENDUM #5**

**DIVISION 10 – SPECIALTIES**

- 101100 VISUAL DISPLAY UNITS
- 101416 PLAQUES
- 101423 ROOM IDENTIFICATION PANEL SIGNAGE
- 102600 WALL AND DOOR PROTECTION
- 102800 TOILET, BATH, AND LAUNDRY ACCESSORIES
- 104413 FIRE EXTINGUISHER CABINETS
- 104416 FIRE EXTINGUISHERS
- 105030 TURNOUT GEAR LOCKERS
- 107310 PROTECTIVE COVERS
- 107516 GROUND SET FLAGPOLES

**DIVISION 11 – EQUIPMENT (NOT USED)**

**DIVISION 12 – FURNISHINGS**

- 122413 ROLLER WINDOW SHADES

**DIVISION 13 – SPECIAL CONSTRUCTION (NOT USED)**

**DIVISION 14 – CONVEYING EQUIPMENT (NOT USED)**

**DIVISION 21 – FIRE SUPPRESSION (NOT USED)**

- 210500 COMMON WORK RESULTS FOR FIRE SUPPRESSION
- 210510 BASIC REQUIREMENTS FOR FIRE SUPPRESSION
- 210517 SLEEVES AND SLEEVE SEALS FOR FIRE SUPPRESSION PIPING
- 210518 ESCUTCHEONS FOR FIRE SUPPRESSION PIPING
- 210529 HANGERS & SUPPORTS FOR FIRE PROTECTION PIPING AND EQUIPMENT
- 210553 IDENTIFICATION FOR FIRE SUPPRESSION PIPING AND EQUIPMENT
- 211313 WET PIPE SPRINKLER SYSTEM

**DIVISION 22 – PLUMBING**

- 220500 COMMON WORK RESULTS FOR PLUMBING
- 220510 BASIC REQUIREMENTS FOR PLUMBING
- 220517 SLEEVES AND SLEEVE SEALS FOR PLUMBING PIPING
- 220518 ESCUTCHEONS FOR PLUMBING PIPING
- 220519 METERS AND GAUGES FOR PLUMBING PIPING
- 220523 GENERAL-DUTY VALVES FOR PLUMBING PIPING
- 220529 HANGERS AND SUPPORTS FOR PLUMBING PIPING AND EQUIPMENT
- 220553 IDENTIFICATION FOR PLUMBING PIPING AND EQUIPMENT
- 220700 PLUMBING INSULATION
- 221116 DOMESTIC WATER PIPING
- 221119 DOMESTIC WATER PIPING SPECIALTIES
- 221120 FACILITY PROPANE GAS PIPING
- 221316 SANITARY WASTE AND VENT PIPING
- 221319 SANITARY WASTE PIPING SPECIALTIES
- 223300 ELECTRIC, DOMESTIC WATER HEATERS
- 224100 PLUMBING FIXTURES

**DIVISION 23 – HEATING, VENTILATING AND AIR CONDITIONING (HVAC)**

**COSA FIRE STATION NO. 53**

**Alamo Architects  
Project No. 2023-04**

**ADDENDUM #5**

230500	COMMON WORK RESULTS FOR HVAC
230510	BASIC REQUIREMENTS FOR HVAC
230513	COMMON MOTOR REQUIREMENTS FOR HVAC
230517	SLEEVES AND SLEEVE SEALS FOR HVAC PIPING
230518	ESCUTCHEONS FOR HVAC PIPING
230529	HANGERS AND SUPPORTS FOR HVAC PIPING AND EQUIPMENT
230548	VIBRATION AND SEISMIC CONTROLS FOR HVAC PIPING AND EQUIPMENT
230553	IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT
230593	TESTING,ADJUSTING AND BALANCING FOR HVAC
230700	HVAC INSULATION
232300	REFRIGERANT PIPING
233113	METAL DUCTS
233300	AIR DUCTS ACCESSORIES
233423	HVAC POWER VENTILATORS
233713	DIFFUSERS, REGISTERS AND GRILLES
235523	PROPANE FIRED RADIANT HEATERS
238126	SPLIT SYSTEM AIR CONDITIONERS
238127	AIR COOLED DUCTLESS MINI SPLIT SYSTEMS
238239	UNIT HEATERS

**DIVISION 26 – ELECTRICAL**

260001	BASIC REQUIREMENTS FOR ELECTRICAL
260519	LOW VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES
260523	CONTROL VOLTAGE ELECTRICAL POWER CABLES
260526	GROUND AND BONDING FOR ELECTRICAL SYSTEMS
260529	HANGERS AND SUPPORTS FOR ELECTRICAL SYSTEMS
260533	RACEWAYS, WIREWAYS AND BOXES
260544	SLEEVE AND SLEEVE SEALS FOR ELECTRICAL RACEWAYS & CABLING
260553	IDENTIFICATION FOR ELECTRICAL SYSTEMS
260923	LIGHTING CONTROL DEVICES
262416	PANELBOARDS
262717	EQUIPMENT WIRING
262726	WIRING DEVICES
262813	FUSES
262816	ENCLOSED SWITCHES AND CIRCUIT BREAKERS
263213	ENGINE GENERATORS
263600	TRANSFER SWITCHES
264113	LIGHTNING PROTECTION FOR STRUCTURES
264313	SURGE PROTECTION DEVICES (SPDS) FOR LOW-VOLTAGE ELECTRICAL POWER CIRCUITS
265100	INTERIOR SOLID-STATE LIGHTNING
265600	EXTERIOR SOLID-STATE LIGHTNING

**DIVISION 27 – COMMUNICATIONS**

271000	STRUCTURED CABLING SYSTEM
272000	US DIGITAL DESIGNS PHOENIX G2 FIRE STATION ALERTING SYSTEM

**DIVISION 28 – SECURITY**

280001	BASIC REQUIREMENTS FOR LOW-VOLTAGE SYSTEMS
280500	SECURITY SYSTEM WIRING
283111	DIGITAL ADDRESSABLE FIRE ALARM SYSTEM

**COSA FIRE STATION NO. 53**

**Alamo Architects**  
**Project No. 2023-04**

**ADDENDUM #5**

DIVISION 31 – EARTHWORK

312300	EXCAVATION AND EMBANKMENT
312323.53	CEMENT STABILIZED SAND BACKFILL
312333	EXCAVATING TRENCHING AND BACKFILLING

DIVISION 32 – EXTERIOR IMPROVEMENTS

321116	SUBGRADE PREPARATION AND COMPACTION
321129	LIME STABILIZATION
321129.02	ROLLING
321300	SITE CONCRETE
321313	CONCRETE PAVEMENT
321613	CONCRETE CURB AND GUTTER
321613.01	CONCRETE SIDEWALK
321723	PAVEMENT MARKINGS
323113	CHAINLINK FENCES AND GATES
323119	DECORATIVE METAL FENCES AND GATES
328400	IRRIGATION
329200	TURF AND GRASSES
329300	PLANTS

DIVISION 33 – UTILITIES

331100	WATER UTILITY DISTRIBUTION
333100	SANITARY UTILITY SEWERAGE
334100	STORM UTILITY DRAINAGE PIPING

APPENDICES

APPENDIX A	EPIC SHEET – <i>PROVIDED BY CITY OF SAN ANTONIO</i>
<b>APPENDIX B</b>	<b>CONSTRUCTION SITE “PROJECT” DISPLAY SIGN DRAWING – <i>PROVIDED BY CITY OF SAN ANTONIO</i></b>

END OF SECTION 000110

# APPENDICES

**COSA FIRE STATION NO. 53**

**Alamo Architects**  
**Project No. 2023-04**

**ADDENDUM #5**

---

**COSA FIRE STATION NO. 53**

**Alamo Architects**  
**Project No. 2023-04**

**ADDENDUM #5**

---

# **APPENDIX A**

**COSA FIRE STATION NO. 53**

**Alamo Architects**  
**Project No. 2023-04**

**ADDENDUM #5**

---

DISCLAIMER: The use of this standard is governed by the "Texas Engineering Practice Act". No warranty of any kind is made by TxDOT for any purpose whatsoever. TxDOT assumes no responsibility for the conversion of this standard to other formats or for incorrect results or damages resulting from its use.

I. STORMWATER POLLUTION PREVENTION-CLEAN WATER ACT SECTION 402

TPDES TXR 150000: Stormwater Discharge Permit or Construction General Permit required for projects with 1 or more acres disturbed soil. Projects with any disturbed soil must protect for erosion and sedimentation in accordance with Item 506. **540**

List MS4 Operator(s) that may receive discharges from this project. They may need to be notified prior to construction activities.

1. **San Antonio Water System**

No Action Required  Required Action

Action No.

1. Prevent stormwater pollution by controlling erosion and sedimentation in accordance with TPDES Permit TXR 150000

2. Comply with the SW3P and revise when necessary to control pollution or required by the Engineer.

3. Post Construction Site Notice (CSN) with SW3P information on or near the site, accessible to the public and TCEQ, EPA or other inspectors.

4. SW3P inspections shall be conducted by a P.E. or a certified stormwater inspector [see COSA Ordinance No. 019-02-14-0123, Sec 34-805(a)].

5. When Contractor specific locations (PSL's) increase disturbed soil area to 5 acres or more, submit NOI to TCEQ and the COSA Inspector.

II. WORK IN OR NEAR STREAMS, WATERBODIES AND WETLANDS CLEAN WATER ACT SECTIONS 401 AND 404

USACE Permit required for filling, dredging, excavating or other work in any water bodies, rivers, creeks, streams, wetlands or wet areas.

The Contractor must adhere to all of the terms and conditions associated with the following permit(s):

No Permit Required

Nationwide Permit 14 - PCN not Required (less than 1/10th acre waters or wetlands affected)

Nationwide Permit 14 - PCN Required (1/10 to <1/2 acre, 1/3 in tidal waters)

Individual 404 Permit Required

Other Nationwide Permit Required: NWP# \_\_\_\_\_

Required Actions: List waters of the US permit applies to, location in project and check Best Management Practices planned to control erosion, sedimentation and post-project TSS.

- 1.
- 2.
- 3.
- 4.

The elevation of the ordinary high water marks of any areas requiring work to be performed in the waters of the US requiring the use of a nationwide permit can be found on the Bridge Layouts.

Best Management Practices:

Erosion	Sedimentation	Post-Construction TSS
<input type="checkbox"/> Temporary Vegetation	<input type="checkbox"/> Silt Fence	<input type="checkbox"/> Vegetative Filter Strips
<input type="checkbox"/> Blankets/Matting	<input type="checkbox"/> Rock Berm	<input type="checkbox"/> Retention/Irrigation Systems
<input type="checkbox"/> Mulch	<input type="checkbox"/> Triangular Filter Dike	<input type="checkbox"/> Extended Detention Basin
<input type="checkbox"/> Sodding	<input type="checkbox"/> Sand Bag Berm	<input type="checkbox"/> Constructed Wetlands
<input type="checkbox"/> Interceptor Swale	<input type="checkbox"/> Straw Bale Dike	<input type="checkbox"/> Wet Basin
<input type="checkbox"/> Diversion Dike	<input type="checkbox"/> Brush Berms	<input type="checkbox"/> Erosion Control Compost
<input type="checkbox"/> Erosion Control Compost	<input type="checkbox"/> Erosion Control Compost	<input type="checkbox"/> Mulch Filter Berm and Socks
<input type="checkbox"/> Mulch Filter Berm and Socks	<input type="checkbox"/> Mulch Filter Berm and Socks	<input type="checkbox"/> Compost Filter Berm and Socks
<input type="checkbox"/> Compost Filter Berm and Socks	<input type="checkbox"/> Compost Filter Berm and Socks	<input type="checkbox"/> Vegetation Lined Ditches
	<input type="checkbox"/> Stone Outlet Sediment Traps	<input type="checkbox"/> Sand Filter Systems
	<input type="checkbox"/> Sediment Basins	<input type="checkbox"/> Grassy Swales

III. CULTURAL RESOURCES

Cultural resources fall under the Antiquities Code of Texas and/or the National Historic Preservation Act, as amended in 1966. If a previously unidentified archeological site is encountered during construction work, activities in the vicinity shall be stopped immediately and the City Archeologist (210-207-5421) and/or the SHPO notified.

No Action Required  Required Action

Action No.

1. If a historic resource (concrete stamp, carriage block, metal fixture, tile, masonry, etc.) is found that is not in the plans or has not been previously assessed, contact the Office of Historic Preservation immediately at (210) 207-0035.

IV. VEGETATION RESOURCES

Preserve native vegetation to the extent practical. Contractor must adhere to Construction Specification Requirements Specs 162, 164, 192, 193, 506, 730, 751, 752 in order to comply with requirements for invasive species, beneficial landscaping, and tree/brush removal commitments.

No Action Required  Required Action

Action No.

1. Ensure that a tree permit is in place for this project, if required.  
2. Follow the tree preservation/mitigation plan provided in the design plan set. If there are any questions or concerns, please contact the City Arborist at (210) 207-0278, before any work begins.

V. FEDERAL LISTED, PROPOSED THREATENED, ENDANGERED SPECIES, CRITICAL HABITAT, STATE LISTED SPECIES, CANDIDATE SPECIES AND MIGRATORY BIRDS.

No Action Required  Required Action

1. MIGRATORY BIRD NESTS: Schedule construction activities as needed to meet the following requirements:

A. Do not remove or destroy any active migratory bird nests (nests containing eggs and/or flightless birds) at any time of year. If there are any active nests, they shall not be removed until the nests become inactive.

B. On/in structures, if there are any active nests, they shall not be removed until all nests become inactive. After inactive nests are removed and/or before nest activity begins, deterrent materials may be applied to the structures to prevent future nest building.

2. Deterrent material should be placed (and maintained) after October 1 or before February 15.  
3. The preferred nesting season for migratory birds is from February 15 through October 1. When practicable, schedule construction operations outside of the preferred nesting season.

4. If any of the listed species are observed, cease work in the immediate area, do not disturb species or habitat and contact the Engineer immediately. The work may not remove active nests from bridges and other structures during nesting season of the birds associated with the nests. If caves or sinkholes are discovered, cease work in the immediate area, and contact the Engineer immediately.

LIST OF ABBREVIATIONS

BMP: Best Management Practice	SPCC: Spill Prevention Control and Countermeasure
CGP: Construction General Permit	SW3P: Storm Water Pollution Prevention Plan
DSHS: Texas Department of State Health Services	PCN: Pre-Construction Notification
FHWA: Federal Highway Administration	PSL: Project Specific Location
MOA: Memorandum of Agreement	TCEQ: Texas Commission on Environmental Quality
MOU: Memorandum of Understanding	TPDES: Texas Pollutant Discharge Elimination System
MS4: Municipal Separate Stormwater Sewer System	TPWD: Texas Parks and Wildlife Department
MBTA: Migratory Bird Treaty Act	TxDOT: Texas Department of Transportation
NOT: Notice of Termination	T&E: Threatened and Endangered Species
NWP: Nationwide Permit	USACE: U.S. Army Corps of Engineers
NOI: Notice of Intent	USFWS: U.S. Fish and Wildlife Service

VI. HAZARDOUS MATERIALS OR CONTAMINATION ISSUES

General (applies to all projects):

Comply with the Hazard Communication Act (the Act) for personnel who will be working with hazardous materials by conducting safety meetings prior to beginning construction and making workers aware of potential hazards in the workplace. Ensure that all workers are provided with personal protective equipment appropriate for any hazardous materials used.

Obtain and keep on-site Material Safety Data Sheets (MSDS) for all hazardous products used on the project, which may include, but are not limited to the following categories: Paints, acids, solvents, asphalt products, chemical additives, fuels and concrete curing compounds or additives. Provide protected storage, off bare ground and covered, for products which may be hazardous. Maintain product labelling as required by the Act.

Maintain an adequate supply of on-site spill response materials, as indicated in the MSDS. In the event of a spill, take actions to mitigate the spill as indicated in the MSDS, in accordance with safe work practices, and contact the District Spill Coordinator immediately. The Contractor shall be responsible for the proper containment and cleanup of all product spills.

Contact the ~~Engineer~~ if any of the following are detected:

- \* Dead or distressed vegetation (not identified as normal)
- \* Trash piles, drums, canister, barrels, etc.
- \* Undesirable smells or odors
- \* Evidence of leaching or seepage of substances

Does the project involve any bridge class structure rehabilitation or replacements (bridge class structures not including box culverts)?

Yes  No

If "No", then no further action is required.

If "Yes", then ~~TxDOT~~ is responsible for completing asbestos assessment/inspection.

Are the results of the asbestos inspection positive (is asbestos present)?

Yes  No

If "Yes", then ~~TxDOT~~ must retain a DSHS licensed asbestos consultant to assist with the notification, develop abatement/mitigation procedures, and perform management activities as necessary. The notification form to DSHS must be postmarked at least 15 working days prior to scheduled demolition.

If "No", then ~~TxDOT~~ is still required to notify DSHS 15 working days prior to any scheduled demolition.

In either case, the Contractor is responsible for providing the date(s) for abatement activities and/or demolition with careful coordination between the Engineer and asbestos consultant in order to minimize construction delays and subsequent claims.

Any other evidence indicating possible hazardous materials or contamination discovered on site. Hazardous Materials or Contamination Issues Specific to this Project:

No Action Required  Required Action

Action No.

- 1.
- 2.
- 3.

VII. OTHER ENVIRONMENTAL ISSUES

(includes regional issues such as Edwards Aquifer District, etc.)

No Action Required  Required Action

Action No.

- 1.
- 2.
- 3.

Fire Station #53

ENVIRONMENTAL PERMITS, ISSUES AND COMMITMENTS EPIC

FILE: epic.dgn	DN: TxDOT	CK: RG	DW: VP	CK: AR
©TxDOT: February 2015	CONT	SECT	JOB	HIGHWAY
12-12-2011 (DS) REVISIONS				
05-07-14 ADDED NOTE SECTION IV.	DIST	COUNTY		SHEET NO.
01-23-2015 SECTION I (CHANGED ITEM 1122 TO ITEM 506, ADDED GRASSY SWALES.				

DATE: FILE:

**COSA FIRE STATION NO. 53**

**Alamo Architects**  
**Project No. 2023-04**

**ADDENDUM #5**

---

# APPENDIX B

**COSA FIRE STATION NO. 53**

**Alamo Architects**  
**Project No. 2023-04**

**ADDENDUM #5**

---



**GENERAL NOTES**

1. SIGN BOARD WILL BE EXTERIOR TYPE HIGH DENSITY OVERLAID 0.5" PLYWOOD OR OTHER APPROVED MATERIAL SUITABLE FOR SIGNS.
2. PROVIDE ADEQUATE SUPPORTS FOR SIGN AS SITE CONDITIONS MAY REQUIRE AND KEEP SIGN PROPER DISTANCE ABOVE PREVAILING GRADE TO PERMIT PUBLIC VIEWING.
3. LEFT BORDER SHALL BE DETERMINED USING THE LONGEST LINE CENTERED ON THE SIGN PROVIDING EQUAL BORDERS.
4. TEXT FONT TYPES WILL BE "CALIBRI" AND "MYRIAD", AS CALLED OUT ON SIGN LAYOUT.
5. DEPARTMENT OF PUBLIC WORKS PROJECTS INVOLVING FACILITIES AND ASSETS BELONGING TO ANOTHER CITY DEPARTMENT, MANAGED ON BEHALF OF SAID DEPARTMENT, WILL UTILIZE THE ALTERNATE "PROJECT" DISPLAY SIGN, FEATURING THE ADDITIONAL "CLIENT" LOGO IDENTIFYING THE BENEFITTING DEPARTMENT, AT THE CONSTRUCTION SITE.

6. THE ADDITIONAL CONSTRUCTION SITE SIGN FEATURING THE UNIQUE "QR" CODE, PROVIDING PUBLIC ACCESS FOR FURTHER PROJECT SPECIFIC INFORMATION AND PUBLIC INPUT, WILL BE PLACED BESIDE THE LARGER MAIN DISPLAY SIGN IDENTIFYING THE PROJECT.
7. THE PUBLIC WORKS DEPARTMENT'S ASSIGNED PROJECT MANAGER WILL PROVIDE THE SPECIFIC URL NAME FOR PLACEMENT INTO THE ADDITIONAL "QR" CODE ACCESSABLE SIGN'S "SASPEAKUP" WEB ADDRESS FEATURED AT THE BOTTOM OF THE SIGN.
8. THE PUBLIC WORKS DEPARTMENT'S ASSIGNED PROJECT MANAGER WILL PROVIDE THE UNIQUE "QR" CODE FOR INSERTION INTO THE ADDITIONAL "FOR MORE INFORMATION..." CONSTRUCTION SITE SIGN.
9. THE PUBLIC WORKS DEPARTMENT'S ASSIGNED PROJECT MANAGER WILL PROVIDE THE WORK OFFICE PHONE NUMBER & EMAIL ADDRESS OF THE PROJECT'S ASSIGNED CAPITOL PROJECTS OFFICER, FOR INCLUSION ON THE MAIN 4 FT. BY 8 FT. CONSTRUCTION SITE "PROJECT" DISPLAY SIGN.

<b>CONSULTANT NAME</b>			
<small>STREET NUMBER AND ADDRESS</small>			
<small>TELEPHONE NUMBER</small>	<small>CITY</small>	<small>STATE</small>	<small>ZIP CODE</small>
	<small>FAX NUMBER</small>		<small>INTERNET ADDRESS</small>
<b>CITY OF SAN ANTONIO</b>			
<small>PUBLIC WORKS DEPARTMENT</small>			
<small>PROJECT TITLE</small>			
<b>CONSTRUCTION SITE</b>			
<b>"PROJECT" DISPLAY SIGN</b>			
<small>PUBLIC WORKS DEPARTMENT STANDARD</small>			
<small>DRWN. BY:</small>	<small>% SUBMITAL PROJECT NO.:</small>	<small>DATE:</small>	
<small>DSGN. BY:</small>	<small>CHKD. BY:</small>	<small>SHEET NO.:</small>	<small>OF</small>



"QR" CODE SPECIFIC FOR THIS PROJECT TO BE PROVIDED BY THE PUBLIC WORKS DEPARTMENT'S ASSIGNED PROJECT MANAGER.

WEB ADDRESS TO THE PUBLIC ACCESS INTERNET RESOURCE FOR INFORMATION SPECIFIC TO THIS PROJECT WILL BE PROVIDED BY THE PUBLIC WORKS DEPARTMENT'S ASSIGNED PROJECT MANAGER.

**GENERAL NOTES**

1. SIGN BOARD WILL BE EXTERIOR TYPE HIGH DENSITY OVERLAID 0.5" PLYWOOD OR OTHER APPROVED MATERIAL SUITABLE FOR SIGNS.
2. PROVIDE ADEQUATE SUPPORTS FOR SIGN AS SITE CONDITIONS MAY REQUIRE AND KEEP SIGN PROPER DISTANCE ABOVE PREVAILING GRADE TO PERMIT PUBLIC VIEWING.
3. LEFT BORDER SHALL BE DETERMINED USING THE LONGEST LINE CENTERED ON THE SIGN PROVIDING EQUAL BORDERS.
4. TEXT FONT TYPES WILL BE "ARIAL BLACK" AND "ARIAL BOLD", AS CALLED OUT ON SIGN LAYOUT.
5. THE ADDITIONAL CONSTRUCTION SITE SIGN FEATURING THE UNIQUE "QR" CODE, PROVIDING PUBLIC ACCESS FOR FURTHER PROJECT SPECIFIC INFORMATION AND PUBLIC INPUT, WILL BE PLACED BESIDE THE LARGER MAIN DISPLAY SIGN IDENTIFYING THE PROJECT.
6. THE PUBLIC WORKS DEPARTMENT'S ASSIGNED PROJECT MANAGER WILL PROVIDE THE SPECIFIC URL NAME FOR PLACEMENT INTO THE ADDITIONAL "QR" CODE ACCESSABLE SIGN'S "SASPEAKUP" WEB ADDRESS FEATURED AT THE BOTTOM OF THE SIGN.
7. THE PUBLIC WORKS DEPARTMENT'S ASSIGNED PROJECT MANAGER WILL PROVIDE THE UNIQUE "QR" CODE FOR INSERTION INTO THE ADDITIONAL "FOR MORE INFORMATION..." CONSTRUCTION SITE SIGN.

<b>CONSULTANT NAME</b>			
<small>STREET NUMBER AND ADDRESS</small>			
<small>CITY</small>		<small>STATE ZIP CODE</small>	
<small>TELEPHONE NUMBER</small>	<small>FAX NUMBER</small>	<small>INTERNET ADDRESS</small>	
<b>CITY OF SAN ANTONIO</b>			
<small>PUBLIC WORKS DEPARTMENT</small>			
<small>PROJECT TITLE</small>			
<b>"QR CODE" ACCESS TO PROJECT INFO. DISPLAY SIGN</b>			
<small>ADDITIONAL SIGN PLACED ADJACENT TO CONSTRUCTION SITE "PROJECT" SIGN</small>			
<small>% SUBMITTAL</small>		<small>PROJECT NO.:</small>	<small>DATE:</small>
<small>DRWN. BY:</small>	<small>DSGN. BY:</small>	<small>CHKD. BY:</small>	<small>SHEET NO. OF</small>